



## **AVOID SAFETY VIOLATIONS AND OSHA CITATIONS**

We have been cited for the following OSHA violations in the past several years. We strive to avoid any violations of health and safety regulations, or OSHA violations. However; future inspections that find a repeat of these following findings can result in greater penalties.

- Scaffolding not completely decked with scaffold grade lumber
- Not using magnetic cutout switch on fixed woodworking tools to prevent automatic restart after a power loss.
- Failure to provide awareness level training for employees working around asbestos containing materials.
- Failure to close mortar mixer hood while mixer is operating.
- Ladder was being used inappropriately on a scaffold.
- Valve extension on an LP tank extended beyond the protective collar of tank.
- Internal short in wiring on circular saw.
- Employee operating Lull was not certified.
- Failure to provide immediate access to SDS.
- Broken blade guard on table saw.
- Use of form stakes with badly mushroomed heads.
- Failure to provide back-up warning signal on Lull.
- Failure to provide handrail at permanent inside stairs.
- Failure to provide handrails at temporary steps to Equipment Trailer.
- Failure to provide working GFCI for electric tool use.
- Exposed welder lead posts on welder generator.



**Please bring anything you think may be a safety violation to the attention of your Supervisor.**