



## LP TANKS

1. LP tanks of 2,000-gallon capacity or less shall not be located within 25 feet of any building. Larger containers shall be at least 50 feet from any building.
2. Portable tanks larger than 660 gallons shall have emergency venting and other devices as required by Chapters II and III of NFPA 30-1969.
3. An access way at least 12 feet wide for firefighting equipment shall be available within 200 feet of each portable tank.
4. LP storage areas shall be kept free of weeds, debris and extraneous materials not required for the storage operations.
5. Storage tanks and containers shall be protected against collision damage.



6. Posting on or around the tank: (NOTE: call your vender to make sure the LP tank comes to your jobsite labeled.)
  - Marked with at least 4-inch letters. (ON BOTH SIDES)
  - No smoking signs
  - Flammable or No Open flames
  - LPG – LP GAS - PROPANE
7. Fuel line hose - needs to be protected from damage. Protect hose from vehicle traffic, equipment and pedestrian damage.
8. 20 lbs. fire extinguisher no closer than 25 feet to, and no farther than 75 feet from, any outside flammable liquid storage area.
9. Tanks shall stand on a firm and substantially level surface.
10. Storage of LP tanks within a building is prohibited.